

Elden Landolt
Mayor

CITY OF LIVERMORE
401 4th Avenue, PO Box 16
Livermore, Iowa 50558
Phone: [515] 379-1074
Fax: [515] 379-2463
Email: livermore@trvnet.net

Janet Berte
Clerk

Sharon Grimm-Berte
Treasurer

Council Members

Paul Brown
Robert Foth
Kelly Frock
Janice Schmieder
William Smith

Aaron Crahan
Fire Chief

Austin Foth
Maintenance

September 30, 2019

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Livermore Water Supply # 4647090 Failed to Comply with a Testing
Procedure

Our water system, Livermore Water Supply, recently failed to comply with a required testing procedure. Even though this was not an emergency, as our customers, you have a right to know what happened and what we did to correct the situation.

**We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 06/30/2019, we did not complete all monitoring or testing for Nitrate and Nitrite, and therefore cannot be sure of the quality of your drinking water during that time. **

What should I do?

There is nothing you need to do at this time. You may continue to drink the water. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

What is being done?

On 8/20/2019 we collected a new sample of our finished water in order to have it analyzed for Nitrate and Nitrite. We sent the sample to the certified lab via courier to ensure that the sample arrived within the allowed holding time. The sample was analyzed and Well #4 (after Treatment) Result was 0.57 mg/L. Well #5 (After Treatment) Nitrite <0.05 mg/L and Nitrate 0.62 mg/L was not found at detectable levels. Maximum Contaminant Level for Nitrate is 10 mg/L. Maximum Contaminant Level for Nitrite is 1 mg/L

For more information, please contact Nicholas Knowles at 515-890-8904.

This notice is being sent to you by Livermore Water Supply, State Water System ID#: 4647090